# CONDUITS ICTA 3422 ORANGE

# Ø 50

**PRODUIT CERTIFIÉ IANOR**
**N° du certificat** :
001/2026

| | | | | |
|---|---|---|---|---|
| STF50 | ATF50 | 50 | 40,09 | 25 |

## CONDUITS ISOLANTS CINTRABLES, TRANSVERSALEMENT ANNELÉS.

**NORMES**
NA CEI 61386 .1
NA CEI 61386.22

**RÉSISTANCE À L'ÉCRASEMENT**
Classe 3, Médium (plus de 750 N sur 5cm à 23 ± 2°C)

**RÉSISTANCE AU CHOCS**
Classe 4, lourde (6 joules à - 5°C)

**TEMPÉRATURE MINIMALE D'EXERCICE**
Classe 2 (-5°C)

**TEMPÉRATURE MAXIMALE D'EXERCICE**
Classe 2 (+90°C)

**RÉSISTANCE À LA PROPAGATION DE LA FLAMME**
Propagateur de flamme (Test d'inflammabilité non applicable)

**RÉSISTANCE ÉLECTRIQUE D'ISOLEMENT**
Plus de 100 mohm (tension de 500 V pour 1 minute)

**RIGIDITÉ DIÉLECTRIQUE**
Plus de 2000V à 50Hz pendant 15 minutes

## PROTECTIVE INSULATING CONDUITS CORRUGATED, PLIABLE.

**STANDARDS**
NA CEI 61386.1
NA CEI 61386.22

**COMPRESSION RESISTANCE**
Class 3 Medium (higher than 750 N on 5cm at 23 ± 2°C)

**IMPACT RESISTANCE**
Class 4, Heavy (6 joules at - 5°C)

**MINIMUM TEMPERATURE RANGE**
Class 2 (-5°C)

**MAXIMUM TEMPERATURE RANGE**
Class 2 (+90°C)

**FLAME PROPAGATION RESISTANCE**
Flame Propagator ( Flammability Test Not Applicable)

**ELECTRIC INSULATING RESISTANCE**
Higher than 100 mohm for 500V in 1 minute

**DIELECTRIC STRENGTH**
Higher than 2000V at 50Hz for 15 minutes

**Adresse** : ZAC Taharacht, 06001 Akbou, Wilaya de Bejaia – ALGERIE
**Tél** : +213(0)34-196 128 | **Fax** : +213(0)34 196 129 | **E-mail** : info@batelec-dz.com
www.batelec-dz.com