CONDUITS ICTA 2222 ORANGE Ø 20

PRODUIT CERTIFIÉ IANOR
N° du certificat :
001/2026

STF20	ATF20	20	14,80	De 50 à 100

CONDUITS ISOLANTS CINTRABLES, TRANSVERSALEMENT ANNELÉS.

PROTECTIVE INSULATING CONDUITS CORRUGATED, PLIABLE.

NORMES
NA CEI 61386 .1
NA CEI 61386.22

RÉSISTANCE À L'ÉCRASEMENT
Classe 2 légère (plus de 320N sur 5cm à 23 ± 2°C)

RÉSISTANCE AU CHOCS
Classe 2, légère (1 joule à - 5°C)

TEMPÉRATURE MINIMALE D'EXERCICE
Classe2 (-5°C)

TEMPÉRATURE MAXIMALE D'EXERCICE
Classe2 (+90°C)

RÉSISTANCE À LA PROPAGATION DE LA FLAMME
Propagateur de flamme (Test d'inflammabilité non applicable)

RÉSISTANCE ÉLECTRIQUE D'ISOLEMENT
Plus de 100 mohm (tension de 500 V pour 1 minute)

RIGIDITÉ DIÉLECTRIQUE
Plus de 2000V à 50Hz pendant 15 minutes

STANDARDS
NA CEI 61386.1
NA CEI 61386.22

COMPRESSION RESISTANCE
Class 2 light (higher than 320N on 5cm at 23 ± 2°C)

IMPACT RESISTANCE
Class 2, light (1 joule at - 5°C)

MINIMUM TEMPERATURE RANGE
Class 2 (-5°C)

MAXIMUM TEMPERATURE RANGE
Class 2 (+90°C)

FLAME PROPAGATION RESISTANCE
Flame Propagator (Flammability Test Not Applicable)

ELECTRIC INSULATING RESISTANCE
Higher than 100mohm for 500V in 1 minute

DIELECTRIC STRENGTH
Higher than 2000V at 50Hz for 15 minutes

Adresse : ZAC Taharacht, 06001 Akbou, Wilaya de Bejaia – ALGERIE
Tél : +213(0)34-196 128 | **Fax** : +213(0)34 196 129 | **E-mail** : info@batelec-dz.com
www.batelec-dz.com